



Certificate of Compliance

Certificate: 1819203

Master Contract: 166449

Project: 1819203

Date Issued: 2006/08/18

Issued to: Foxboro-Eckardt GmbH

Pragstrasse 82
Stuttgart, 70376
Germany
Attention: Mr. Karl Gatterer

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ron Wildish

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 1, Groups C and D; Class II, Div. 1, Groups E, F and G; Class III, Div. 1; Type 4X:

Models 244LD and 244LVP Intelligent Buoyancy Transmitters; input rated 12-42 Vdc, 4-20 mA; Temp. Code T4, -40 Deg. C < Tamb. < +85 Deg. C; Temp. Code T6, -40 Deg. C < Tamb. < +75 Deg. C; MWP 710 psi.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations



Certificate: 1819203

Master Contract: 166449

Project: 1819203

Date Issued: 2006/08/18

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 142-M1987 - Process Control Equipment



Supplement to Certificate of Compliance

Certificate: 1819203

Master Contract: 166449

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1819203	2006/08/18	Model 244 LD and 244 LVP Buoyancy Transmitters for hazardous locations.